



Georg Fischer Harvel LLC  
7777 Sloane Drive  
Little Rock AR, 72206  
USA  
T +1 501 490 7777  
F +1 501 490 7171  
us.ps@georgfischer.com  
www.gfps.com

Benjamin Levie  
T +1 501 490 7367  
F +1 501 490 7171  
M +1 501 322 0712  
Benjamin.levie@georgfischer.com

Little Rock, April 22, 2020

Dear Valued Customer,

This letter is to certify that CPVC Schedule 40 & 80 Pipe manufactured by Georg Fischer Harvel LLC complies with the following.

Item	Standard	Notes
Material used for pipe	ASTM D1784 "Standard Specification for Rigid Polyvinyl Chloride Compounds and Chlorinated Polyvinyl Chloride Compounds	CPVC Type IV material as defined by ASTM F441. Meet cell class 23447
Material used for pipe	FM4910, UL-94 rating of V-0, 5VB, 5VA	Listed by FM Global
Material used for Pipe	Corzan®	Manufactured by Lubrizol
Product s marked NSF-pw or NSF 61	NSF61	Listed by NSF
Product marked NSF-pw	NSF 14, California AB 1953-NSF 61 Annex G (NSF/ANSI 372)	Listed by NSF (listing includes required ASTM product standards), exceeds California lead-free requirement
Products marked cNSF-uspw	CSA 137.6	Complies
Products marked ULC	ULC S102.2-M88	Complies
All product marked "Made in USA or "USA"	FTC requirements for unqualified marking "Made in USA" and Buy America Act	All Pipe Complies

Page 2/2

Yours sincerely

Georg Fischer Piping Systems Ltd.

A handwritten signature in black ink, appearing to read 'Benjamin Levie', written in a cursive style.

Benjamin Levie  
Product Manager, Vinyl Piping Systems